



Rough Inspection Checklist – Drain-Waste-Vent

Address:	Contractor:	Permit #
<i>The following checklist is not all-inclusive. Other code related requirements may be included in this inspection.</i>		
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 103.1.2 Verify work conforms with plans:	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC Tables 7-3, 7-5, 3-2 SEC. 708.0, Check drainage pipe size, slope and support:	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 316.1.6, 706.0 Check proper use of fittings and direction of flow and for use of proper glue on plastic pipe:	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC Tables 7-3, 7-5 Check vent piping size with regard to vent pipe length and fixture load:	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC Table 10.1 Check trap arm lengths and correct vent orientation with respect to trap:	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 906.0 Check vent terminations through the roof:	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 908.1 Verify that proper wet venting procedures are followed:	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 707.0 Table 7-6 Check for cleanouts (location and clearance):	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
		UPC 313.9 Check for nail plates:
		UPC 313.2 Check for proper notching and boring of studs and joist:
		UPC 408.7, ADA Standards Fig 4-28 Check ADA clearances for toilets:
		UPC 909.0 Verify proper island venting procedures are followed:
		UPC 804.1 Washing machine stand pipe and trap:
		UPC 707.1.2 Check for piping in return air plenums:
		UPC 412.0 Check for required floor drains locations:
		UPC 910.0 Check combination waste and vent systems for compliance:

OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 712.2, 712.3 Check for air or water test on cast DWV	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 1014.0, 1016.0 Check proper installation of grease or sand traps
Notes:			
Date		Inspector	

Draft